


## MARDEN VILLAGE DRAINS











Marden Hereford HR1 3EN

25th February 2021

## MARDEN DRAINAGE CHECK

Number on map	Condition/action required
1-4 area	Chambers full, no improvement from jetting, needs gulley sucker and recycle vacuum
	Advise needs redesign of whole system on corner, major civils project, raise road level and put in proper land drainage
5	Ditch running but is not deep enough, washing debris into culvert pipe
12, 34, 35	There are problems in the main requiring a recycled vac unit to clear the mains.

Jetted, checked, draining well

## Mark Price

6-11, 13-33, 36-65



